

Certificate of Type-examination

No.: 10229021/AA/00

Telefication declares that the stated alarm equipment complies with the Technical specifications as listed in Annex 2 of this certificate.

Product description: **8m volumetric PIR motion sensor with 5 curtains**
Trademark: **See annex 3**
Family name: **--**
Type designation: **See annex 3**
Serial No: **See annex 3**
Hard- / Softw. release No: **PCB rev1 / -**


Manufacturer: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003 DH Weert**
Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003 DH Weert**
Country: **Netherlands**

This certificate has THREE Annexes.

Zevenaar, 12 January 2011



W.J.M. Jong
Operations Manager
Certification



Remarks and observations

The following conditions are applicable:

Equipment Security grade: 2
Equipment Environmental class: II
Operating temperature: from -10 up to 55 degrees Celcius.
Equipment class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including security grade 2
Electrical safety, clause 13 of EN 50131-1:2006 was not performed.

All versions have identical electronics and housing,
but are different with respect to the mirror.
PIR range < 10 m / 6 m (selectable) for EV100(PI) PI=Pet Immuun
PIR range < 12 m / 7 m (selectable) for EV105

Documentation lodged for this type-examination

Test Reports:

- Telefication B.V.: 20103444800_Rev.1, 01 December 2010
- VdS GmbH: STE 01/0240, 26 September 2001

Product Documentation:

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual

Technical Standards and Specifications

The product shows no non-compliances with:

- | | |
|-----------------|---------------|
| - EN 50130-4 | December 1995 |
| - EN 50130-4/A1 | April 1998 |
| - EN 50130-4/A2 | January 2003 |
| - EN 50130-5 | December 1998 |
| - EN 50131-2-2 | January 2008 |

Technical features and characteristics

The product includes the following features and characteristics:

Not specified

The product as described in this Certificate includes the following type designations:

Product description: 8m volumetric PIR motion sensor with 5 curtains
Type designation: EV100
Trademark: Interlogix
Serial No: --
Hard- / Softw. release No: PCB rev1 / -

Product description: 8m volumetric PIR motion sensor with 5 curtains
Type designation: EV100PI
Trademark: Interlogix
Serial No: --
Hard- / Softw. release No: PCB rev1 / -

Product description: 8m volumetric PIR motion sensor with 5 curtains
Type designation: EV105
Trademark: Interlogix
Serial No: --
Hard- / Softw. release No: PCB rev1 / -